



Power Systems Electric, Inc.

1261 Little Mountain Road

Myerstown, P.A. 17067

Phone # (800) 875-6964

General Operating Guidelines

Compliance with the following recommendations is necessary and may result in longer life, and better performance and dependability of your emergency generator set.

Weekly Maintenance Schedule

The following checks should be performed and recorded in attached chart, weekly.

Before Starting

Fuel Level
Lube oil level
Coolant level & cleanliness of radiator
Engine heater operating
Test run generator for 30 minutes

While Operating

Oil pressure
Water temperature
A.C. voltage
A.C. amperage
A.C. Hz

Monthly Maintenance Schedule

The following checks should be performed and recorded in attached chart, monthly.

Before Starting

Check coolant protection level
Battery water level & voltage

Load test system by simulating a power failure. Run under load for minimum of 1 hour. Record performance. Annually full load test for minimum of 4 hours. Any questions or improper operations observed please call qualified service personnel at **(800) 875-6964!**